

Republic of the Philippines Department of Environment and Natural Resources ENVIRONMENTAL MANAGEMENT BUREAU Region VIII

DENR Compound, Jones Street, Barangay 2, Tacloban City Tel No: (053) 832-10-88

Permit No: PTO-OL-R08-2021-05784 Date Issued: 28 Jul 2021
Application Type: New Date Expiration: 28 Jul 2026

PERMIT TO OPERATE Air Pollution Source and Control Installations

Pursuant to Part IV, Rule XIX of the Rules and Regulations of R.A. 8749, authority is hereby granted to:

Jollibee Catbalogan (Jollibee Catbalogan)

Allen Avenue, Poblacion 3 (Barangay 3), City Of Catbalogan (Capital), Samar (Western Samar)

subject to the following terms and conditions:

TERMS AND CONDITIONS

- This Permit is issued for the permittee to operate one (1) unit "CUMMINS" Diesel Generator Set rated at 160 KW
 for the purpose of Standby Power at the permittee's establishment identified on this Permit. (Refer to attached Annex
 at page 2)
- 2. Any application for renewal of this Permit shall be filed not less than **thirty (30) days** before the expiry date indicated on the previous page of the Permit.
- 3. The previous page of this Permit shall be posted in a conspicuous location of the premises, and shall be adequately framed or otherwise protected against damage.
- 4. Without limiting the generality of the previous condition, the permittee shall ensure that the emissions from the permitted installations or processes comply with:
 - the National Emission Standards for Source Specific Air Pollutants as specified in Rule XXV of the IRRs of RA 8749:
 - the National Ambient Air Quality Standards for Source Specific Air Pollutants from Industrial Sources/Operations as specified in Rule XXVI of the IRRs of 8749.
- 5. The permittee shall submit **Self-Monitoring Reports (SMR)** to the Bureau in accordance with DENR Administrative Order No. 27 (Series of 2003) and any written instructions by the Bureau at three-monthly intervals, commenting with submission of the first Report on or before **October 15, 2021**.(Online submission at https://client.emb.gov.ph/smr)
- 6. The permittee shall at all times have an appointed or designated **Pollution Control Officer (PCO)** pursuant to DAO 2014-02.
- 7. The permittee shall at all times allow authorized or accredited officers of the Department or the Bureau entry to the establishment and access to any part of the establishment to conduct inspections, gather information, test emissions or take samples.
- 8. The permittee shall not make or allow any alterations or modifications to operations, activities, installations, processes, plant or equipment at the establishment that might substantially change the nature or quantity of the associated emissions without obtaining the approval of the Bureau, including the obtaining of any necessary Permit to Operate.
- 9. The permittee shall burn only **Diesel Fuel** in the **one (1) unit 160 KW "CUMMINS" Standby Generator Set** for not more than **500 annual operating hours** for the whole duration of the permit validity.

Recommended by:

Approved by:

MARIBEL B. MUNSAYAC
Chief, Clearance and Permitting Division

ENGRI REYNALDO B. BARI

φIC-Regional Director

 Filing Fee
 : Php 600.00
 O.R. No. : OR No. 4737024, 4736298
 Date : 19 July 2021

 Permit Fee
 : Php 2500.00
 O.R. No. : OR No. 4737024, 4736298
 Date : 19 July 2021

 PD1856
 : Php 10.00
 O.R. No. : OR No. 4737024, 4736298
 Date : 19 July 2021

 Documentary Stamp Tax
 : Php 30.00
 O.R. No. : OR No. 4737024, 4736298
 Date : 19 July 2021



Annex

Fuel Burning					
ID	APSI	Capacity	Brand name	Type of Fuel	APCD
85653	Generator Set	160.0 kW	Cummins	Diesel	

Filing Fee : Php 600.00 O.R. No.: OR No. 4737024, 4736298 Date: 19 July 2021 : Php 2500.00 Permit Fee O.R. No. : OR No. 4737024, 4736298 Date : 19 July 2021 PD1856 : Php 10.00 O.R. No. : OR No. 4737024, 4736298 Date: 19 July 2021 Date: 19 July 2021 Documentary Stamp Tax : Php 30.00 O.R. No. : OR No. 4737024, 4736298

