ENVIRONMENTAL MANAGEMENT BUREAU REGION 8



COMPLIANCE INSPECTION FOR AIR QUALITY MANAGEMENT

ENVIRONMENTAL MONITORING AND ENFORCEMENT DIVISION-WATER AIR QUALITY MONITORING SECTION

1. GENERAL INFORMATION				
Name of Establishment: DJ CONCF				
Address: MAHARLIKA HIGHWAY, BRGY. 95-A CAIBAAN TACLOBAN CITY		Geo Coordinates 11.1958832 °N 124.9915756 °E		
Nature of Business: BATCHING PL				
PSIC Code: 2396	Product: READY-MIXED CONCRETE	Year Established:	2013	
Operating hours/day: 8	Operating days/week: 6	Operating days/y	ear:	
Product Lines	Production Rate as Declared in the ECC (unit/day)	Actual Pro	duction Rate (unit/day)	
Ready-mixed concrete mixture	50 MT/DAY	25 MT/DAY (based on Q4 2021 SMR)	
Name of Managing Head:	MYLENE L. JULIO			
Name of PCO:	DARYL DEXTER L. JULIO			
PCO Accreditation No.:	2016-RVIII-0025	Date of Effectivity: 02/11/2016		
Phone/Fax:	09173108324	Email: djconcre	tesolutions@gmail.com	
2. PURPOSE OF INSPECTION				
☐ Verify accuracy of information su	ibmitted by the establishment p	ertaining to new p	ermit applications,	
renewals, or modification				
New Renewal PMPIN Application		New	Renewal	
Hazardous Waste ID Registi	ration			
Hazardous Waste Transpor				
Hazardous waste TSD Regis				
Permit to Operate Air Pollu				
Discharge Permit	tion control histaliation			
Others				
ouncis				
□ Determine compliance status w	ith the environmental regulation			
requirements	the environmental regulation	is, permit conditio	ns, and other	
☐ Investigate community complain	ats			
☐ Check status of voluntary comm				
Industrial Ecowatch	The state of the s			
	ortnorchin Deserve (2522)			
Philippine Environmental Pa Pollution Adjudication Boar	a (DAB)			
Others				
Name of Contact Person Position / Designation				

3. COMPLIANCE STATUS

3.1 DENR Permits/Licenses/Clearance

Environmental Law		Permits	Date of Issue	Expiry Date
	ECC1	ECC-R08-1306-0072	07/08/2013	
PD 1586	ECC2			
	ECC3			
	DENR Registry ID			
RA 6969	PCL Compliance Certificate			
	CCO Registry			
	Permit to Transport			
RA 8749	POA No.	POA-2020-B-0837-0032	02/17/2020	02/26/2025
RA 9003	ECC for Sanitary Landfill			
RA 9275	DP No.	DP-R08-20-05356	11/12/2020	11/12/2021

MODULE AQM01: PRE-INSPECTION INFORMATION SHEETFOR EMISSION SOURCES

Emission Sou	rce Data Information
Emission Source No.	1 & 2
Type (Brand/Model)	Concrete Batching Plant (2 units)
Rated Capacity	51 MT/HR
Fuel Type & Quantity	Electrically driven
Operating Capacity	
Control Facility	Dust collector
Notes:	

Emission Source No.	3
Type (Brand/Model)	Denyo genset (1 unit)
Rated Capacity	176 KW
Fuel Type & Quantity	diesel
Operating Capacity	standby
Control Facility	
Notes	

Legal Provision	Regulatory Requirements	Co	ompl	iant	Notes
		Υ	N	N/A	
DAO 2004-26			-		
Rule 19 Section 1	All emission sources have a valid Permit to Operate	1			POA valid until 02/26/2025
Rule 19 Section 3	As built design of the installation conforms with submitted engineering plans and specifications	1			
	Declared control facilities are installed and operational	1			
	Installation is located as proposed in the vicinity map (plant and machinery layout)	1			
	Facility design capacity is within the capacity declared in the application for permit to operate	1			
Rule 19 Section 5	Temporary Permit is still valid			1	
Rule 19 Section 6	Application for renewal has been filed for expiring Permit to Operate 30 days before permit expiration date			1	
Rule 19 Section 9	Permit to Operate displayed conspicuously upon the installation or in an accessible / visible place near the installation	1			

	Conditions of the Permit to Operate are complied with	/			
Rulle 19 Section 11	Plant operational problems notification submitted to EMB within 24 hours of occurrence		/		
Rule 19 Section 12	Quarterly submission of self- monitoring report	1		Q ₁ Q ₃	Q ₂ Q ₄ 01/18/2022
DAO 2000-81					
Part 7 Rule 25 Section 5 a#	Person in charge of the plant / equipment has sufficient measure to ensure that no dark smoke is discharging from any stack in the establishment. E.g.: window view of stack, mirror to reflect top of stack, smoke density indicator, CCTV, etc.		/		
Part 7 Rule 25 Section 5 a# 2	All oil-burning equipment have heaters capable of heating oil to a temperature appropriate for the oil and burner		1		
Part 7 Rule 25 Section 5 a# 3	Establishment is fossil fuel-fired power plant over 10MW rating installed with CEMS for particulates, sulfur oxide, and NOx		/		
	Establishment is petroleum refinery / petrochemical industry installed with CEMS for particulates, sulfur oxide, and NOx		/		
	Establishment is primary copper smelter installed with CEMS for particulates, sulfur oxide, and NOx		/		
	Establishment is steel plant installed with CEMS for particulates and sulfur oxide		/		
	Establishment is ferro-alloy production facility installed with CEMS for particulates		/		
	Establishment is cement plant installed with CEMS for particulates		1		
Part 7 Rule 25 Section 5 b	Miscellaneous equipment like reheating furnace, smoke oven, bake oven, coffee heaters, varnish kettles, etc. are installed with pollution control facilities		1		
Part 7 Rule 25 Section 13 a	Establishment has precautionary controls for dusts generated during vehicular movement, transportation of materials, construction, etc. (List controls identified)		/		
Part 7 Rule 25 Section 13 b	Establishment has precautionary controls for volatile organic compounds or organic solvent emissions generated during storing, pumping, handling, processing, etc. (Listcontrols identified)		/		
Part 7 Rule 25 Section 13 d	No open burning activity in the establishment	1			

EMB Memorandum Circ	NOTE OF THE PARTY		
MC 2009-04	Standby Gensets with capacity greater than or equal to 1,250 KW undergo annual emission testing (with 3 test runs). These gesets should not have the potential to emit more than 100tons/year of regulated pollutant.		
MC 2007-003 (2)	Boiler rated at greater than or equal to 251HP undergo bi-annual emission testing (with 3 test runs)	/	
	Other sources that have potential to emit equal to or greater than 100tons/year of regulated pollutant undergo bi-annual emission testing (with 3 test runs)	/	
	Boiler rated between 100 to 250 HP undergo annual emission testing (with 3 test runs)	/	
	Diesel generator rated at 600 to 1,249KW undergo annual testing (with 3 test runs)	/	
	Other sources that have potential to emit greater than 30 but less than 100tons/year of regulated pollutant undergo annual emission testing (with 3 test runs)		
	Sources of emissions of hazardous air pollutants included in PCL (DAO 1998 -58) undergo bi-annual emission testing (with 3 test runs)	/	
	Emission sources of petroleum refinery undergo bi-annual emission testing (with 3 test runs)	/	
	Emission sources of petrochemical works undergo bi-annual emission testing (with 3 test runs)	/	
	Emission sources of smelters undergo bi-annual emission testing (with 3 test runs)	/	
	Emission sources of cement kilns undergo bi-annual emission testing 'with 3 test runs)	1	
	Emission sources of steel -making plants undergo bi-annual emission testing (with 3 test runs)	/	

	Emission sources of ferro-alloy- making plants undergo bi-annual emission testing (with 3 test runs)	1	
	Emission sources of glass-making plants undergo bi-annual emission testing (with 3 test runs)	1	
	Boiler rated at 99HP or less undergo biennial emission testing (with 3 test runs)	1	
	Diesel generator rated at 599KW or less undergo biennial emission testing (with 3 test runs)	1	
	Other sources that have potential to emit at least 10tons/year but less than 30tons/year of regulated pollutant undergo biennial emission testing (with 3 test runs)	1	
	Source using Bunker Fuel Oil, blended fuels involving Bunker Fuel Oil, or sulfur content of 1% or more undergo bi-annual emission testing	1	
Annendix E (Quality As	eurance Procedures)		
	Notification has been sent to EMB for any changes made in the CEMS installation	1	
	Notification has been sent to EMB for any changes made in the CEMS	1	
Section 6 (8)	Notification has been sent to EMB for any changes made in the CEMS installation Notification has been sent to EMB for any changes made in the CEMS quality assurance and quality control		
Section 6 (8) Section 6 (5)	Notification has been sent to EMB for any changes made in the CEMS installation Notification has been sent to EMB for any changes made in the CEMS quality assurance and quality control plan Each CEMS is audited and conducted in accordance to CFR 40	1	
Appendix F (Quality As Section 6 (8) Section 6 (5)	Notification has been sent to EMB for any changes made in the CEMS installation Notification has been sent to EMB for any changes made in the CEMS quality assurance and quality control plan Each CEMS is audited and conducted in accordance to CFR 40 part 60 Appendix F. Relative Accuracy Test Audit (RATA) is performed annually by industries in	1	

	Other alternative quarterly audits employed by the establishment are approved by EMB.	1	
Section 6 (9)	EMB Director and Regional Director have been notified of CEMS malfunction that lasted longer than seven (7) consecutive days.	1	
Section 7 (1)	Records of occurrence and duration of any start-up, shut-down or malfunction in the operation of any source or control facility is available in the establishment.	1	
Section 7 (2)	Records of audits, performance testing, evaluations, calibration checks, adjustments and maintenance of any continuous emission monitors that have been installed pursuant to Rule IX Section 5 of DAO 2000-81 are available in the establishment.	/	
Section 8 (1)	SMR includes data on the time intervals, date and magnitude of excess emissions, nature and cause of excess, corrective actions taken, and preventive measures adopted.	1	
Section 8 (2)	SMR includes information on the averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant/source category in question.	1	
Section 8 (3)	SMR includes information on time and date for each period during which the continuous monitoring system was inoperative and the nature of system repairs and adjustments made in the CEMS/COMS	1	
Section 8 (4)	SMR data measurements are within 75% data capture?	1	
For Facilities Engaged wit	h Consent Agreement		
EMS established within 18 months upon entering Consent Agreement with EMB	EMS established within 18 months upon entering Consent Agreement with EMB	1	
DAO 2000-81 Part 7 Rule 25 Section 9b	Environmental Management Plan derived from EMS process submitted within 6 months after entering Consent Agreement with EMB	1	

Other Observations:

- Permit to Operate Air is valid until February 26, 2025 for the 2 units concrete batching plants and one unit 176 KW Denyo diesel engine standby generator set.
- SMR is submitted quarterly through the online system. Only one-unit concrete batching plant is reflected in Module 4 of the SMR.
- Discharge Permit expired on November 12, 2021. Application fore renewal was lodged online on October 27, 2021 and returned to proponent on November 1, 2021 for submission of latest effluent result.

Remarks and Recommendation:

- Properly accomplish Module 4 of SMR to indicate all required data (process equipment) and corresponding details on operation.
- For PCO to apply for renewal of accreditation.
- ✓ Comply with the submission of latest effluent result in DP application.

List of Documents Reviewed:

Copy of the valid Permit to Operate

Submitted by:

JO ANNE JOY M. DAÑAL-VILLERO

Senior EMS

Recommended by:

Noted by:

Engr. CARLOS A. CAYANONG

Engineer IV/Chief, WAQMS

Approved by:

FOR. MANUEL J. SACEDA, JR.

OIC Chief, EME

EVALA DO P. PARPA PM

IC, Regional Director



Republic of the Philippines Department of Environment and Natural Resources ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII

DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City



DISPOSITION FORM

Doc. Date: February 15, 2022

: R8-2022-006435

Company Name: DJ CONCRETE SOLUTIONS INC., BRGY. 95-A

CAIBAAN, TACLOBAN CITY



Subject / Title: Compliance Monitoring Report - Air (Table Monitoring) for DJ Concrete Solutions, Inc.

TO: All Officials/Personnel Concerned:

Please accomplish and route this properly with the corresponding attached communication/documents. The Official or employee in-charge to whom this document is routed shall act promptly and expeditiously without discrimination as prescribed in the SECSIME or within fifteen (15) working days from receipt thereof, failure to do is punishable by LAW under RA 6713 and negligence to Memorandum Circular No. 44 issued by the Office of the President of the Philippines "Directing all Government Agencies and Instrumentalities, including government-owned or controlled corporations to respond to all public requests and concerns within 15 days (15 from the receipt thereof)

For strict compliance.

IIS No.

		R	ROUTED	
BY (Official Code/ Sender Initial)	DATE (mm/dd/yy)	TO (Official Code/ Receiver Initial)	TIME (AM/PM)	ACTION REMARKS STATUS
Jo Anne Joy M. Dañal	02/15/2022	Carlos A. Cayanong	08:23 PM	For initial/signature.
C. EMED	02/18/22	040		
RO	FEB 1 8 202	22 EMEDY Niña	8:43om	Noted Signed

Use code for comment/instruction and desired action:

A - For information / guidance / reference

B - For comments / recommendations

C - Pls. take up with me

D - Pls. draft answer memo

E - Pls. appropriatte action I - For initial/signature

F - Pls. immediate investigation J - For study/evaluation

G - Pls. Attach supporting papers K - Pls. release/file

H - Pls. for approval L - Update stat of case

Important Reminder!

Do not tamper. Continue on separate sheet if necessary. Attach this always with the document to be routed as this shall form an integral part of the document process.