



Republic of the Philippines  
Department of Environment and Natural Resources  
**ENVIRONMENTAL MANAGEMENT BUREAU**  
Region VIII  
DENR Compound, Jones Street, Barangay 2, Tacloban City  
Tel No: (053) 832-10-88

Permit No: PTO-OL-R08-2021-08814  
Application Type: New

Date Issued: 25 Oct 2021  
Date Expiration: 25 Oct 2026

**PERMIT TO OPERATE**  
**Air Pollution Source and Control Installations**

Pursuant to Part IV, Rule XIX of the Rules and Regulations of R.A. 8749, authority is hereby granted to:

**NPC-LIBUCAN DIESEL POWER PLANT**  
**(NPC-LIBUCAN DIESEL POWER PLANT)**

**Sugod, Tarangnan, Samar (Western Samar)**

subject to the following terms and conditions:

**TERMS AND CONDITIONS**

1. This Permit is issued for the permittee to operate **one (1) unit "PERKINS" Diesel Generator Set** rated at **80 KW**; **one (1) unit "FG WILSON" Diesel Generator Set** rated at **80 KW**; and **one (1) unit "CUMMINS" Diesel Generator Set** rated at **80 KW**; for the purpose of **Power Generation**, respectively at the permittee's establishment identified on this Permit. *(Refer to attached Annex at page 2)*
2. Any application for renewal of this Permit shall be filed **not less than thirty (30) days** before the expiry date indicated on this Permit.
3. This Permit shall be posted in a conspicuous location of the premises, and shall be adequately framed or otherwise protected against damage.
4. Without limiting the generality of the previous condition, the permittee shall ensure that the emissions from the permitted installations or processes comply with:
  - the National Emission Standards for Source Specific Air Pollutants as specified in Rule XXV of the IRRs of RA 8749; and
  - the National Ambient Air Quality Standards for Source Specific Air Pollutants from Industrial Sources/Operations as specified in Rule XXVI of the IRRs of 8749.
5. The permittee shall submit Self-Monitoring Reports to the Bureau in accordance with DENR Administrative Order No. 27 (Series of 2003) and any written instructions by the Bureau at three-monthly intervals, commencing with submission of the **first Report** on or before **January 15, 2022**. (Online Submission at <https://client.emb.gov.ph/smr>)
6. The permittee shall at all times have an appointed or designated Pollution Control Officer (PCO) pursuant to DAO 2014-02.
7. The permittee shall at all times allow authorized or accredited officers of the Department or the Bureau entry to the establishment and access to any part of the establishment to conduct inspections, gather information, test emissions or take samples.
8. The permittee shall not make or allow any alterations or modifications to operations, activities, installations, processes, plant or equipment at the establishment that might substantially change the nature or quantity of the associated emissions without obtaining the approval of the Bureau, including the obtaining of any necessary Permit to Operate.
9. The permittee shall burn only **Diesel Fuel Oil** in the **one (1) unit 80 KW"PERKINS" Diesel Generator Set; one (1) unit 80 KW "FG WILSON" Diesel Generator Set; and one (1) unit 80 KW "CUMMINS" Diesel Generator Set** for the whole duration of the permit validity


Recommended by:

Approved by:

Filing Fee	: Php 600.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
Permit Fee	: Php 7500.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
PD1856	: Php 10.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

  
**MARIBEL B. MUNSAAYAC**  
Chief, Clearance and Permitting Division

  
**ENGR. REYNALDO B. BARRA**  
PIC-Regional Director

Filing Fee	: Php 600.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
Permit Fee	: Php 7500.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
PD1856	: Php 10.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

Annex

Fuel Burning					
ID	APSI	Capacity	Brand name	Type of Fuel	APCD
131514	Unit No. 2	80.0 kW	PERKINS	DIESEL FUEL OIL	---
131515	Unit No. 3	80.0 kW	FG WILSON	DIESEL FUEL OIL	---
131516	Unit No. 4	80.0 kW	CUMMINS	DIESEL FUEL OIL	---

Filing Fee	: Php 600.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
Permit Fee	: Php 7500.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
PD1856	: Php 10.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 226-10062021-208401	Date : Oct. 6, 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.