



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 074

Customer

Facility Name: Courtyard by Marriott
Address: 401 West Waterfront Drive
West Homestead, PA 15120

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 8/12/25
Time: 10:00 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/13/25 | 10:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/13/25 | 10:30 AM | EB | SM 9222B |
| Standard plate count: | 250/ml | 200/ml | 8/12/25 | 5:00 PM | SL | SM 9215B |
| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
| Fecal Streptococcus | 0/100mls | 2/100mls | 8/13/25 | 11:30 AM | EB | SM 9230C |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.2 SU | 7.2 - 7.8 SU | 8/12/25 | 10:00 AM | BL | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 8/12/25 | 10:00 AM | BL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/12/25 | 10:00 AM | BL | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 074

Customer

Facility Name: Courtyard by Marriott
Address: 401 West Waterfront Drive
West Homestead, PA 15120

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 8/12/25
Time: 10:00 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/13/25 | 10:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/13/25 | 10:30 AM | EB | SM 9222B |
| Standard plate count: | 250/ml | 200/ml | 8/12/25 | 5:00 PM | SL | SM 9215B |
| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
| Fecal Streptococcus | 0/100mls | 2/100mls | 8/13/25 | 11:30 AM | EB | SM 9230C |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.2 SU | 7.2 - 7.8 SU | 8/12/25 | 10:00 AM | BL | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 8/12/25 | 10:00 AM | BL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/12/25 | 10:00 AM | BL | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor