



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 047**

**Customer**

Facility Name: *Chartiers Valley H.S.*  
  
Address: *50 Thoms Run Road*  
*Bridgeville, PA 15017*

Matrix: *Recreational Water*

Source Type: *Deep End*

**Sample Collection**

Date: *6/9/25*  
Time: *10:30 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *6/12/25*  
Time: *9:30 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/9/25	10:30 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	10:30 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	10:30 AM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 047**

**Customer**

**Facility Name:** Chartiers Valley H.S.  
**Address:** 50 Thoms Run Road  
Bridgeville, PA 15017

**Matrix:** Recreational Water

**Source Type:** Deep End

**Sample Collection**

**Date:** 6/9/25  
**Time:** 10:30 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/12/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/9/25	10:30 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	10:30 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	10:30 AM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor