



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 251

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Penn Trafford High School	Date:	2/16/26			
Address:	3381 Rt. 130 Harrison City, PA 15636	Time:	1:43 PM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	2/18/26			
	Pool	Time:	10:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	2/17/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/17/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/16/26	5:08 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	2/16/26	1:43 PM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/16/26	1:43 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/16/26	1:43 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor