



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 365

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Road
Sewickley, PA 15143
Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 8/6/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25 3:40 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/6/25 4:50 PM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/6/25 12:30 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/6/25 12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25 12:30 PM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 365

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Road
Sewickley, PA 15143
Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 8/6/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/6/25	4:50 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/6/25	12:30 PM	VH
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/6/25	12:30 PM	VH
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	12:30 PM	VH

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor