



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2363

Customer

Facility Name: Mount Vernon Apts
Address: 2300 Surrey Lane
McKeesport, PA 15135

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/5/25
Time: 12:51 PM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25 5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/5/25 12:51 PM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/5/25 12:51 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25 12:51 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2363

Customer

Facility Name: Mount Vernon Apts
Address: 2300 Surrey Lane
McKeesport, PA 15135

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/5/25
Time: 12:51 PM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	8/5/25	12:51 PM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/5/25	12:51 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	12:51 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor