



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 290

Customer

Facility Name: Springhill Suites
Address: 16 Trinity Point Dr.
Washington, PA 15301

Sample Collection

Date: 11/24/25
Time: 9:38 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 11/27/25
Time: 10:00 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	11/25/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/25/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	11/24/25	4:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/24/25	9:38 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/24/25	9:38 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/24/25	9:38 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)