



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 296

Customer

Facility Name: Steel Valley High School

Address: 3113 Main Street
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 5/27/25

Time: 1:00 PM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/27/25	1:00 PM	DW	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/27/25	1:00 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	1:00 PM	DW	Visual

Sample comments



(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 296

Customer

Facility Name: Steel Valley High School

Address: 3113 Main Street
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 5/27/25

Time: 1:00 PM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/27/25	1:00 PM	DW	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/27/25	1:00 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	1:00 PM	DW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor