

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 216

CustomerSample CollectionFacility Name:Longwood at OakmontDate: 6/3/25Time: 2:05 PMAddress:500 Route 909Method: GrabVerona, PA 15147Sample Final Analysis

Matrix: Recreational Water Date: 6/6/25

1 - 2 NTU

1 NTU

Source Type: Spa Time: 9:30 AM
Analyst: AS

**Accredited Analysis** Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 6/4/25 11:00 AM AH SM 9222G Total coliforms: 0/100mls 2/100mls 6/4/25 11:00 AM AH SM 9222B 200/ml 6/3/25 4:45 PM EΒ SM 9215B Standard plate count: 0/ml **Additional Analysis** Results Reporting limit **Analyst Incubation Date/Time** Method AΗ Fecal Streptococcus 0/100mls 2/100mls 6/4/25 12:00 PM SM 9230C **Field Analysis** Results Reporting limit Date/Time **Analyst** Method 7.2 - 7.8 SU 7.6 SU DPD pH: 6/3/25 2:05 PM BH Chlorine: 2.0 mg/l 1.0 - 5.0 mg/l 6/3/25 2:05 PM BH DPD

6/3/25

## Sample comments

Turbidity:

andre Smith

2:05 PM

BH

Visual

( When exceeding reporting limit pool or spa is unfit)



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 216

CustomerSample CollectionFacility Name:Longwood at OakmontDate: 6/3/25Time: 2:05 PMAddress:500 Route 909Method: GrabVerona, PA 15147Sample Final Analysis

Matrix: Recreational Water Date: 6/6/25

1 - 2 NTU

1 NTU

Source Type: Spa Time: 9:30 AM
Analyst: AS

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 6/4/25 11:00 AM AH SM 9222G Total coliforms: 0/100mls 2/100mls 6/4/25 11:00 AM AH SM 9222B 200/ml 6/3/25 4:45 PM EΒ SM 9215B Standard plate count: 0/ml **Additional Analysis** Results Reporting limit **Analyst Incubation Date/Time** Method AΗ Fecal Streptococcus 0/100mls 2/100mls 6/4/25 12:00 PM SM 9230C **Field Analysis** Results Reporting limit Date/Time **Analyst** Method 7.2 - 7.8 SU 7.6 SU DPD pH: 6/3/25 2:05 PM BH Chlorine: 2.0 mg/l 1.0 - 5.0 mg/l 6/3/25 2:05 PM BH DPD

6/3/25

## Sample comments

Turbidity:

andre Smith

2:05 PM

BH

Visual

( When exceeding reporting limit pool or spa is unfit)