



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-1**

**Lab# 044**

**Customer**

**Facility Name:** Carnegie Mellon  
**Address:** 5000 Forbes Ave.  
Pittsburgh, PA 15213

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 11/4/25  
**Time:** 9:42 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 11/7/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/5/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/5/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/4/25	3:20 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	11/5/25	10:10 AM	SL	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	11/4/25	9:42 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/4/25	9:42 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/4/25	9:42 AM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor