



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 354**

**Customer**

Facility Name: YMCA - Butler

Address: 339 North Washington St.  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Small Pool

**Sample Collection**

Date: 7/16/25

Time: 11:54 AM

Method: Grab

**Sample Final Analysis**

Date: 7/19/25

Time: 8:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/17/25	10:10 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/17/25	10:10 AM	SL	SM 9222B
Standard plate count:	200/ml	200/ml	7/16/25	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/16/25	11:54 AM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/16/25	11:54 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/16/25	11:54 AM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 354**

**Customer**

Facility Name: YMCA - Butler

Address: 339 North Washington St.  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Small Pool

**Sample Collection**

Date: 7/16/25

Time: 11:54 AM

Method: Grab

**Sample Final Analysis**

Date: 7/19/25

Time: 8:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/17/25	10:10 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/17/25	10:10 AM	SL	SM 9222B
Standard plate count:	200/ml	200/ml	7/16/25	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/16/25	11:54 AM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/16/25	11:54 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/16/25	11:54 AM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor