



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 236**

**Customer**

Facility Name: North Hills H.S.  
Address: 53 Rochester Road  
Pittsburgh, PA 15229

**Sample Collection**

Date: 6/24/25  
Time: 9:32 AM  
Method: Grab

**Sample Final Analysis**

Date: 6/27/25  
Time: 9:20 AM  
Analyst: AS

Matrix: Recreational Water  
Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	11:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	9:32 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	9:32 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	9:32 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 236**

**Customer**

Facility Name: North Hills H.S.  
Address: 53 Rochester Road  
Pittsburgh, PA 15229

**Sample Collection**

Date: 6/24/25  
Time: 9:32 AM  
Method: Grab

**Sample Final Analysis**

Date: 6/27/25  
Time: 9:20 AM  
Analyst: AS

Matrix: Recreational Water  
Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	11:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	9:32 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	9:32 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	9:32 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor