



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2041

Customer

Facility Name: *Berkshire Estate*
Address: *6000 Middle Field Dr.*
McDonald, PA 15057

Sample Collection

Date: *8/26/25*
Time: *7:54 AM*
Method: *Grab*

Sample Final Analysis

Date: *8/29/25*
Time: *10:30 AM*
Analyst: *AS*

Matrix: *Recreational Water*
Source Type: *Baby Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	11:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	4:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/26/25	7:54 AM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/26/25	7:54 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	7:54 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor