



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2018

Customer

Facility Name: Ammon
Address: 2217 Bedford Ave
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 8/5/25
Time: 12:45 PM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 10:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25 5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25 12:45 PM	WB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	8/5/25 12:45 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25 12:45 PM	WB	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2018

Customer

Facility Name: Ammon
Address: 2217 Bedford Ave
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 8/5/25
Time: 12:45 PM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 10:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25 5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25 12:45 PM	WB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	8/5/25 12:45 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25 12:45 PM	WB	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor