

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2453

Customer

Facility Name:

Rosedale Beach

Address:

5407 3rd St.

Verona, PA 15147

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date: Time: 7/15/25 2:00 PM

Method: Grab

Sample Final Analysis

Date:

7/18/25 9:30 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	АН	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	АН	SM 9222B	
Standard plate count:	0/ml	200/ml	7/15/25	3:28 PM	EB	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25	2:00 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/15/25	2:00 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	2:00 PM	EH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2453

Customer

Facility Name:

Rosedale Beach

Address:

5407 3rd St.

Verona, PA 15147

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date: Time: 7/15/25 2:00 PM

Method: Grab

Sample Final Analysis

Date:

7/18/25 9:30 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	АН	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	АН	SM 9222B	
Standard plate count:	0/ml	200/ml	7/15/25	3:28 PM	EB	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25	2:00 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/15/25	2:00 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	2:00 PM	EH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor