



**1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

CP

Lab# 2359

<b><u>Customer</u></b>		<b><u>Sample Collection</u></b>				
Facility Name:	Moore	Date:	8/19/25			
Address:	1801 Pioneer Ave. Pittsburgh, PA 15226	Time:	8:54 AM			
Matrix:		<b><u>Sample Final Analysis</u></b>				
Source Type:	Recreational Water	Date:	8/22/25			
	Deep End	Time:	9:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/20/25	9:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	9:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/19/25	8:54 AM	CC	DPD
Chlorine:	3.5 mg/l	1.0 - 5.0 mg/l	8/19/25	8:54 AM	CC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	8:54 AM	CC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor