Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2522

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name:	*Terrain Apts*	**Sample Collection**
		Date: 6/16/25
		Time: 3:27 PM
Address:	*700 Mansfield Road*	*Method:* Grab
	Pittsburgh, PA, 15205	
		Sample Final Analysis
Matrix:	*Recreational Water*	*Date:* 6/19/25
		Time: 10:00 AM
Source Type:	*Pool*	*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	3:27 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	3:27 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	3:27 PM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer	*American Pools Management* *3261 Babcock Blvd.* *Pittsburgh, PA 15237*

Facility Name:	*Terrain Apts*	**_Sample Collection_** *Date:* 6/16/25 *Time:* 3:27 PM
Address:	*700 Mansfield Road* *Pittsburgh, PA, 15205*	*Method:* Grab
Matrix:	*Recreational Water*	**_Sample Final Analysis_** *Date:* 6/19/25 *Time:* 10:00 AM
Source Type:	*Pool*	*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	3:27 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	3:27 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	3:27 PM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor