



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 151

Customer

Facility Name: Hilton Garden Inn
Address: 1000 Corporate Dr.
Cannonsburg, PA 15317

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/5/26
Time: 11:38 AM
Method: Grab

Sample Final Analysis

Date: 1/8/26
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/6/26	9:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/6/26	9:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/5/26	2:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	1/5/26	11:38 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/5/26	11:38 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/5/26	11:38 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)