Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2453

Customer

		Sample Collection	
Facility Name:	Rosedale Beach	*Date:*	7/28/25
		Time:	12:34 PM
Address:	5407 3rd St.	*Method:*	Grab
	Verona, PA 15147		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	7/31/25
		Time:	9:00 AM
Source Type:	Pool	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	12:34 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	12:34 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	12:34 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2453

Customer

Facility Name:	Rosedale Beach
Address:	5407 3rd St.
	Verona, PA 15147
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection

Date:	7/28/25
Time:	12:34 PM
Method:	Grab

Sample Final Analysis

Date:	7/31/25
Time:	9:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	12:34 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	12:34 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	12:34 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor