



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-10

Lab# 020

Customer

Facility Name: Beaver Area HS
Address: Gypsy Glen
Beaver, PA 15009

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/11/25
Time: 2:29 PM
Method: Grab

Sample Final Analysis

Date: 8/14/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	11:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	2:29 PM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/11/25	2:29 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	2:29 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-10

Lab# 020

Customer

Facility Name: Beaver Area HS
Address: Gypsy Glen
Beaver, PA 15009

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/11/25
Time: 2:29 PM
Method: Grab

Sample Final Analysis

Date: 8/14/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	11:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	2:29 PM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/11/25	2:29 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	2:29 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor