



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2361**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Bracken House*  
*Address:*      *100 Anderson St.*  
*Pittsburgh, PA 15212*

*Date:*      *8/19/25*  
*Time:*      *12:15 PM*  
*Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*  
*Source Type:*      *Pool*

*Date:*      *8/22/25*  
*Time:*      *9:00 AM*  
*Analyst:*      *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/19/25	12:15 PM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/19/25	12:15 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	12:15 PM	LM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor