



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2134

**Customer**

Facility Name: Crafton Borough Pool

Address: 117 W. Steuben St.  
Crafton, PA 15205

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 5/28/25

Time: 10:30 AM

Method: Grab

**Sample Final Analysis**

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:25 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	10:30 AM	VH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/28/25	10:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	10:30 AM	VH	Visual

**Sample comments**



( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2134

**Customer**

Facility Name: Crafton Borough Pool

Address: 117 W. Steuben St.  
Crafton, PA 15205

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 5/28/25

Time: 10:30 AM

Method: Grab

**Sample Final Analysis**

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:25 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	10:30 AM	VH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/28/25	10:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	10:30 AM	VH	Visual

**Sample comments**



( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor