



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041  
N-17

Lab# 2067

**Customer**

Facility Name: *Butler Country Club*  
Address: *310 Country Club Lane*  
*Butler, PA 16002*

Matrix: *Recreational Water*

Source Type: *Small Pool*

**Sample Collection**

Date: *5/27/25*  
Time: *12:00 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *5/30/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	10:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:50 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:50 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041  
N-17

Lab# 2067

**Customer**

Facility Name: *Butler Country Club*  
Address: *310 Country Club Lane*  
*Butler, PA 16002*

Matrix: *Recreational Water*

Source Type: *Small Pool*

**Sample Collection**

Date: *5/27/25*  
Time: *12:00 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *5/30/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	10:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:50 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:50 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor