



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 429**

**Customer**

Facility Name: Upper St. Clair High School

Address: 1825 McLaughlin Run Rd.  
Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Dive Deep

**Sample Collection**

Date: 2/3/26

Time: 1:50 PM

Method: Grab

**Sample Final Analysis**

Date: 2/6/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/4/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/4/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/3/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	2/3/26	1:50 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/3/26	1:50 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/3/26	1:50 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor