



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 069**

**Customer**

**Facility Name:** Cornell High School  
**Address:** 1099 Maple St  
Coraopolis, PA 15108

**Matrix:** Recreational Water

**Source Type:** Shallow End

**Sample Collection**

**Date:** 2/2/26  
**Time:** 9:59 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 2/5/26  
**Time:** 11:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/3/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/3/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/2/26	5:03 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/2/26	9:59 AM	AMH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	2/2/26	9:59 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/2/26	9:59 AM	AMH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)