



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2449**

**Customer**

**Facility Name:** *Rodgers-McFeely*  
  
**Address:** *910 Jefferson Street*  
*Latrobe, PA 15650*

**Sample Collection**

**Date:** *6/24/25*  
**Time:** *2:00 PM*  
**Method:** *Grab*

**Sample Final Analysis**

**Matrix:** *Recreational Water*  
  
**Source Type:** *Pool*

**Date:** *6/27/25*  
**Time:** *9:20 AM*  
**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/25/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	10:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.2 SU	7.2 - 7.8 SU	6/24/25	2:00 PM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	2:00 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	2:00 PM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaë Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2449**

**Customer**

Facility Name: *Rodgers-McFeely*  
  
Address: *910 Jefferson Street*  
*Latrobe, PA 15650*

**Sample Collection**

Date: *6/24/25*  
Time: *2:00 PM*  
Method: *Grab*

**Sample Final Analysis**

Matrix: *Recreational Water*  
  
Source Type: *Pool*

Date: *6/27/25*  
Time: *9:20 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	10:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/24/25	2:00 PM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	2:00 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	2:00 PM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaë Smith*