

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

NI 4.4

N-14

Lab ID No. 02-04041

Lab# 2036

Customer

Facility Name: Bellvue Park

Address: Lambeth Dr.

Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 6/9/25

 Time:
 12:51 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 6/12/25

 Time:
 9:30 AM

 Analyst:
 AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	2:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
рН:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:51 PM	ZR	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:51 PM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:51 PM	ZR	Visual	

Sample comments

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

andre Smith



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

NI 4.4

N-14

Lab ID No. 02-04041

Lab# 2036

Customer

Facility Name: Bellvue Park

Address: Lambeth Dr.

Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 6/9/25

 Time:
 12:51 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 6/12/25

 Time:
 9:30 AM

 Analyst:
 AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	2:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
рН:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:51 PM	ZR	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:51 PM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:51 PM	ZR	Visual	

Sample comments

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

andre Smith