



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 390**

**Customer**

**Facility Name:** *Fairfield Inn & Suites*  
**Address:** *1000 University Parkway*  
*Slippery Rock, PA 16057*

**Matrix:** *Recreational Water*

**Source Type:** *Spa*

**Sample Collection**

**Date:** *6/2/25*  
**Time:** *2:10 PM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/5/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/25	11:30 AM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	2:10 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/2/25	2:10 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	2:10 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 390**

**Customer**

**Facility Name:** *Fairfield Inn & Suites*  
**Address:** *1000 University Parkway*  
*Slippery Rock, PA 16057*

**Sample Collection**

**Date:** *6/2/25*  
**Time:** *2:10 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *6/5/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

**Source Type:** *Spa*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/3/25	10:00 AM	AH	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	6/3/25	10:00 AM	AH	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	6/3/25	11:30 AM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	2:10 PM	BH	DPD
-----	--------	--------------	--------	---------	----	-----

Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/2/25	2:10 PM	BH	DPD
-----------	----------	----------------	--------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/2/25	2:10 PM	BH	Visual
------------	-------	-----------	--------	---------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor