



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 253**

**Customer**

Facility Name: *Perry Traditional Academy*

Address: *3875 Perrysville Ave.  
Pittsburgh, PA 15214*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

**Sample Collection**

Date: *11/17/25*

Time: *2:46 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *11/20/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	11/18/25	11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	11/18/25	11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	A	11/17/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	11/17/25	2:46 PM	MM	DPD
Chlorine:	3.0 mg/l	A	11/17/25	2:46 PM	MM	DPD
Turbidity:	1 NTU	A	11/17/25	2:46 PM	MM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)