



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 449**

**Customer**

**Facility Name:** Super 8 Hotel  
**Address:** 2001 Leesburg Grove City Rd.  
Mercer, PA 16137

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 8/4/25  
**Time:** 3:45 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/7/25  
**Time:** 11:20 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	3:45 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/4/25	3:45 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	3:45 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 449**

**Customer**

**Facility Name:** Super 8 Hotel  
**Address:** 2001 Leesburg Grove City Rd.  
Mercer, PA 16137

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 8/4/25  
**Time:** 3:45 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/7/25  
**Time:** 11:20 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	3:45 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/4/25	3:45 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	3:45 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor