



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 369

**Customer**

Facility Name: Towne Place Suites Grove city

Address: 231 Westside Square r.  
Mercer, PA 16137

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 5/27/25

Time: 3:50 PM

Method: Grab

**Sample Final Analysis**

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	3:50 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/25	3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	3:50 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 369

**Customer**

Facility Name: Towne Place Suites Grove city

Address: 231 Westside Square r.  
Mercer, PA 16137

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 5/27/25

Time: 3:50 PM

Method: Grab

**Sample Final Analysis**

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	3:50 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/25	3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	3:50 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor