

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E - 10

Lab ID No. 02-04041

Lab# 002

Sample Collection Customer

Facility Name: Aerobics Center Date: 6/10/25 Time: 10:56 AM

526 New Alexandria Road Address: Method: Grab

Greensburg, PA 15601 Sample Final Analysis

Recreational Water Date: 6/13/25 Matrix: Time: 9:30 AM

Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	3:12 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.8 SU	7.2 - 7.8 SU	6/10/25	10:56 AM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/10/25	10:56 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	10:56 AM	JC	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E - 10

Lab ID No. 02-04041

Lab# 002

Sample Collection Customer

Facility Name: Aerobics Center Date: 6/10/25 Time: 10:56 AM

526 New Alexandria Road Address: Method: Grab

Greensburg, PA 15601 Sample Final Analysis

Recreational Water Date: 6/13/25 Matrix: Time: 9:30 AM

Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	3:12 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.8 SU	7.2 - 7.8 SU	6/10/25	10:56 AM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/10/25	10:56 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	10:56 AM	JC	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)