



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 009

Customer

Facility Name: Arsenal Middle
Address: 3900 Butler St.
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 7/23/25
Time: 3:15 PM
Method: Grab

Sample Final Analysis

Date: 7/25/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/23/25	4:27 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/23/25	4:27 PM	SL	SM 9222B
Standard plate count:	0/ml	A	7/23/25	4:27 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	7/23/25	3:15 PM	CW	DPD
Chlorine:	3.0 mg/l	A	7/23/25	3:15 PM	CW	DPD
Turbidity:	1 NTU	A	7/23/25	3:15 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 009

Customer

Facility Name: Arsenal Middle
Address: 3900 Butler St.
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 7/23/25
Time: 3:15 PM
Method: Grab

Sample Final Analysis

Date: 7/25/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/23/25	4:27 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/23/25	4:27 PM	SL	SM 9222B
Standard plate count:	0/ml	A	7/23/25	4:27 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	7/23/25	3:15 PM	CW	DPD
Chlorine:	3.0 mg/l	A	7/23/25	3:15 PM	CW	DPD
Turbidity:	1 NTU	A	7/23/25	3:15 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor