

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2733

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Fox Plan Sample Collection

Date: 5/29

 Fox Plan
 Date:
 5/29/25

 Time:
 1:45 PM

 105 Fox Plan Rd.
 Method:
 Grab

Address: 105 Fox Plan Rd. Me Monroeville, PA 15146

Matrix: Recreational Water Sample Final Analysis

Date: 5/31/25

Source Type: Pool Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	5:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	5:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	4:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	5/29/25	1:45 PM	ZR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/29/25	1:45 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	1:45 PM	ZR	Visual

Sample comments

anobie Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2733

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Fox Plan Sample Collection

Date: 5/29

 Fox Plan
 Date:
 5/29/25

 Time:
 1:45 PM

 105 Fox Plan Rd.
 Method:
 Grab

Address: 105 Fox Plan Rd. Me Monroeville, PA 15146

Matrix: Recreational Water Sample Final Analysis

Date: 5/31/25

Source Type: Pool Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	5:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	5:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	4:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	5/29/25	1:45 PM	ZR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/29/25	1:45 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	1:45 PM	ZR	Visual

Sample comments

anobie Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor