



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 169

Laboratory Analysis Report

Customer

Facility Name: Homewood Suites
Address: 200 GSK Dr.
Moon Township, PA 15108

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 10/1/25
Time: 11:20 AM
Method: Grab

Sample Final Analysis

Date: 10/3/25
Time: 4:30 PM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 10/1/25 | 4:00 PM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/1/25 | 4:00 PM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/1/25 | 3:10 PM | JC | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 10/1/25 | 11:20 AM | BH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 10/1/25 | 11:20 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/1/25 | 11:20 AM | BH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor