



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2766**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Greenwood*

*Date: 8/26/25*

*Address: 412 Greenwood Dr.*  
*Canonsburgh, PA 15317*

*Time: 1:12 PM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 8/29/25*

*Source Type: Pool*

*Time: 10:30 AM*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	8/27/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	4:30 PM	AS	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.8 SU	7.2 - 7.8 SU	8/26/25	1:12 PM	GR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/26/25	1:12 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	1:12 PM	GR	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor