

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2232

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Green Acres Apts. Date: 7/28/25
Time: 11:50 AM

Address: 208 Litman Road Method: Grab

Butler, PA 16001

Matrix: Recreational Water Sample Final Analysis

Date: 7/31

Matrix: Recreational Water Date: 7/31/25 Time: 9:00 AM

Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	11:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	11:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	11:50 AM	ВН	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:50 AM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:50 AM	ВН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2232

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Green Acres Apts. Date: 7/28/25
Time: 11:50 AM

Address: 208 Litman Road Method: Grab

Butler, PA 16001

Matrix: Recreational Water Sample Final Analysis

Date: 7/31

Matrix: Recreational Water Date: 7/31/25 Time: 9:00 AM

Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	11:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	11:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	11:50 AM	ВН	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:50 AM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:50 AM	ВН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor