

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**C-11**

**Lab# 032**

**Customer**

**Facility Name:** Cambria Suites  
**Address:** 1320 Centre Ave  
Pittsburgh, PA 15219

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/8/25  
**Time:** 10:40 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/11/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/9/25 9:30 AM	AH	SM 9222G
-------------------	--------	--------	----------------	----	----------

Total coliforms:	0/100mls	2/100mls	7/9/25 9:30 AM	AH	SM 9222B
------------------	----------	----------	----------------	----	----------

Standard plate count:	0/ml	200/ml	7/8/25 4:30 PM	AH	SM 9215B
-----------------------	------	--------	----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/9/25 11:00 AM	AH	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	7/8/25 10:40 AM	LM	DPD
-----	--------	--------------	-----------------	----	-----


Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/8/25 10:40 AM	LM	DPD
-----------	-----------	----------------	-----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	7/8/25 10:40 AM	LM	Visual
------------	-------	-----------	-----------------	----	--------

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**C-11**

**Lab# 032**

**Customer**

**Facility Name:** Cambria Suites  
  
**Address:** 1320 Centre Ave  
Pittsburgh, PA 15219

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/8/25  
**Time:** 10:40 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/11/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/9/25 9:30 AM	AH	SM 9222G
-------------------	--------	--------	----------------	----	----------

Total coliforms:	0/100mls	2/100mls	7/9/25 9:30 AM	AH	SM 9222B
------------------	----------	----------	----------------	----	----------

Standard plate count:	0/ml	200/ml	7/8/25 4:30 PM	AH	SM 9215B
-----------------------	------	--------	----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/9/25 11:00 AM	AH	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	7/8/25 10:40 AM	LM	DPD
-----	--------	--------------	-----------------	----	-----

Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/8/25 10:40 AM	LM	DPD
-----------	-----------	----------------	-----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	7/8/25 10:40 AM	LM	Visual
------------	-------	-----------	-----------------	----	--------

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor