Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# **399**

Customer

Facility Name:	*Stay Bridge Suites*
Address:	*915 Brush Creek Rd.*
	Warrendale, PA 15086
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/23/25*
Time:	*9:55 AM*
Method:	*Grab*

Sample Final Analysis

Date:	*6/26/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/23/25	9:55 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	9:55 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	9:55 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# **399**

Customer

Facility Name:	*Stay Bridge Suites*
Address:	*915 Brush Creek Rd.*
	Warrendale, PA 15086
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/23/25*
Time:	*9:55 AM*
Method:	*Grab*

Sample Final Analysis

Date:	*6/26/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/23/25	9:55 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	9:55 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	9:55 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)