



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 1

Lab# 2001

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: 1400 Main @ Southpointe

Address: 1400 Main St.
Canonsburg, PA 15317

Sample Collection

Date: 7/1/25
Time: 12:26 PM
Method: Grab

Matrix: Recreational Water

Source Type: Spa

Sample Final Analysis

Date: 7/4/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|----------------------------|----------------|------------------------|--------------------------------------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 7/2/25 11:20 AM | EB | SM 9222G |

| | | | | | |
|-----------------------|----------|----------|--------------------------------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 7/2/25 11:20 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/1/25 5:45 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|----------------------------|----------------|------------------------|--------------------------------------|----------------|---------------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/2/25 11:40 AM | AH | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|-----------------------|----------------|------------------------|--------------------------------------|----------------|---------------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 7/1/25 12:26 PM | AF | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/1/25 12:26 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/1/25 12:26 PM | AF | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 1

Lab# 2001

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: 1400 Main @ Southpointe

Address: 1400 Main St.
Canonsburg, PA 15317

Sample Collection

Date: 7/1/25
Time: 12:26 PM
Method: Grab

Matrix: Recreational Water

Source Type: Spa

Sample Final Analysis

Date: 7/4/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|----------------------------|----------------|------------------------|--------------------------------------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 7/2/25 11:20 AM | EB | SM 9222G |

| | | | | | |
|-----------------------|----------|----------|--------------------------------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 7/2/25 11:20 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/1/25 5:45 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|----------------------------|----------------|------------------------|--------------------------------------|----------------|---------------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/2/25 11:40 AM | AH | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|-----------------------|----------------|------------------------|--------------------------------------|----------------|---------------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 7/1/25 12:26 PM | AF | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/1/25 12:26 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/1/25 12:26 PM | AF | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor