

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2685

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name:

Marquis Place

Address:

1000 Marquis Pl

Murrysville PA 15668

Matrix:

Recreational Water

Source Type:

**Accredited Analysis** 

Pool

Results

Absent

Sample Collection

Date: Time: 7/15/25 7:22 AM

Method:

Grab

Sample Final Analysis

Date: Time: 7/18/25

Analyst:

9:30 AM AS

Incubation Date/Time Analyst Method

Escherichia Coli:
Total coliforms:

0/100mls

2/100mls 7/16/25

9:35 AM

ΑH

AΗ

SM 9222B

SM 9222G

Standard plate count:

0/ml

200/ml

Absent

**Reporting limit** 

7/15/25

7/16/25

3:28 PM

9:35 AM

EΒ

SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/15/25	7:22 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/15/25	7:22 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	7:22 AM	EH	Visual

Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2685

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name:

Marquis Place

Address:

1000 Marquis Pl

Murrysville PA 15668

Matrix:

Recreational Water

Source Type:

**Accredited Analysis** 

Pool

Results

Absent

Sample Collection

Date: Time: 7/15/25 7:22 AM

Method:

Grab

Sample Final Analysis

Date: Time: 7/18/25

Analyst:

9:30 AM AS

Incubation Date/Time Analyst Method

Escherichia Coli:
Total coliforms:

0/100mls

2/100mls 7/16/25

9:35 AM

ΑH

AΗ

SM 9222B

SM 9222G

Standard plate count:

0/ml

200/ml

Absent

**Reporting limit** 

7/15/25

7/16/25

3:28 PM

9:35 AM

EΒ

SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/15/25	7:22 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/15/25	7:22 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	7:22 AM	EH	Visual

Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor