



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665**

Lab ID No. 02-04041

W-2

Lab# 179

**Laboratory Analysis Report**

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Hyatt Place	Date:	10/7/25			
Address:	6011 Campbells Run Rd Pittsburgh, PA 15205	Time:	10:45 AM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	10/10/25			
	Pool	Time:	10:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	10/8/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/8/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/7/25	4:10 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	10/7/25	10:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	10/7/25	10:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/7/25	10:45 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor