

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **APM 1** 

Lab# 2024

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Avalon Boro

Address: 629 New Brighton Rd.

Avalon, PA 15202

Matrix: Recreational Water

Results

Absent

Source Type: Shallow End

Sample Collection

 Date:
 7/1/25

 Time:
 2:07 PM

Method: Grab

Sample Final Analysis

11:05 AM

Incubation Date/Time

7/2/25

Date: 7/4/25
Time: 9:30 AM
Analyst: AS

**Analyst** 

FB

Method

SM 9222G

Esononia con.	71000111	71000111	172720	11.00741	LD	OW SZZZO
Total coliforms:	0/100mls	2/100mls	7/2/25	11:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:37 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	2:07 PM	MM	DPD
pH: Chlorine:	7.6 SU 3.0 mg/l	7.2 - 7.8 SU 1.0 - 5.0 mg/l	7/1/25 7/1/25	2:07 PM 2:07 PM	MM MM	DPD DPD

Reporting limit

Absent

## Sample comments

**Accredited Analysis** 

Escherichia Coli:

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **APM 1** 

Lab# 2024

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Avalon Boro

Address: 629 New Brighton Rd.

Avalon, PA 15202

Matrix: Recreational Water

Results

Absent

Source Type: Shallow End

Sample Collection

 Date:
 7/1/25

 Time:
 2:07 PM

Method: Grab

Sample Final Analysis

11:05 AM

Incubation Date/Time

7/2/25

Date: 7/4/25
Time: 9:30 AM
Analyst: AS

**Analyst** 

FB

Method

SM 9222G

Esononia con.	71000111	71000111	172720	11.00741	LD	OW SZZZO
Total coliforms:	0/100mls	2/100mls	7/2/25	11:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:37 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	2:07 PM	MM	DPD
pH: Chlorine:	7.6 SU 3.0 mg/l	7.2 - 7.8 SU 1.0 - 5.0 mg/l	7/1/25 7/1/25	2:07 PM 2:07 PM	MM MM	DPD DPD

Reporting limit

Absent

## Sample comments

**Accredited Analysis** 

Escherichia Coli:

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor