Lab ID No. 02-04041

**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**
**Laboratory Analysis Report**

**E - 11**

***Lab#  2449***

*Customer*

| | | |
|---|---|---|
| *Facility Name:* | *Rodgers-McFeely* | |
| *Address:* | *910 Jefferson Street* | |
| | *Latrobe, PA 15650* | |
| *Matrix:* | *Recreational Water* | |
| *Source Type:* | *Pool* | |

*Sample Collection*

| | |
|---|---|
| *Date:* | *8/4/25* |
| *Time:* | 2:00 PM |
| *Method:* | *Grab* |

*Sample Final Analysis*

| | |
|---|---|
| *Date:* | *8/7/25* |
| *Time:* | *11:20 AM* |
| *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/5/25 | 10:50 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/5/25 | 10:50 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/4/25 | 4:21 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4  SU | 7.2 - 7.8 SU | 8/4/25 | 2:00 PM | JC | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/4/25 | 2:00 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 | 2:00 PM | JC | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andrea Smith*

# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Lab ID No. 02-04041

**E - 11**

**Lab#  2449**

---

**Customer**

| | | | **Sample Collection** | |
|---|---|---|---|---|
| *Facility Name:* | *Rodgers-McFeely* | | *Date:* | *8/4/25* |
| | | | *Time:* | 2:00 PM |
| *Address:* | *910 Jefferson Street* | | *Method:* | *Grab* |
| | *Latrobe, PA 15650* | | | |
| | | | **Sample Final Analysis** | |
| *Matrix:* | *Recreational Water* | | *Date:* | *8/7/25* |
| | | | *Time:* | *11:20 AM* |
| *Source Type:* | *Pool* | | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/5/25 | 10:50 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/5/25 | 10:50 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/4/25 | 4:21 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4  SU | 7.2 - 7.8 SU | 8/4/25 | 2:00 PM | JC | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/4/25 | 2:00 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 | 2:00 PM | JC | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andrea Smith*