



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 219

Laboratory Analysis Report

Customer

Facility Name: Marriott Airport
Address: 777 Aten Rd.
Coraopolis, PA 15108

Sample Collection

Date: 1/27/26
Time: 8:45 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 1/30/26
Time: 10:30 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/28/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/28/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/27/26	5:16 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	1/27/26	8:45 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	1/27/26	8:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/27/26	8:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor