



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2758

Customer

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Outdoor Splash Pad

Sample Collection

Date: 7/28/25

Time: 11:42 AM

Method: Grab

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25 10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25 10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25 4:45 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25 11:42 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/28/25 11:42 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25 11:42 AM	JC	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2758

Customer

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Outdoor Splash Pad

Sample Collection

Date: 7/28/25

Time: 11:42 AM

Method: Grab

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25 10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25 10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25 4:45 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25 11:42 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/28/25 11:42 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25 11:42 AM	JC	Visual

Sample comments



(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor