



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2736

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Prism at Diamond Ridge*

Address: *1000 Prism Place*
Moon Twp. PA 15108

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/1/25*

Time: *10:45 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/4/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	10:45 AM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/1/25	10:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	10:45 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2736

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Prism at Diamond Ridge*

Address: *1000 Prism Place*
Moon Twp. PA 15108

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/1/25*

Time: *10:45 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/4/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	10:45 AM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/1/25	10:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	10:45 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor