



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 349

Customer		Sample Collection				
Facility Name:	Courtyard - University Center	Date:	11/18/25			
Address:	100 Lytton Ave. Pittsburgh, PA 15213	Time:	9:56 AM			
					Sample Final Analysis	
Matrix:	Recreational Water	Date:	11/21/25			
Source Type:	Pool	Time:	10:00 AM			
Accredited Analysis		Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent		11/19/25	10:30 AM	AS SM 9222G
Total coliforms:	0/100mls	2/100mls		11/19/25	10:30 AM	AS SM 9222B
Standard plate count:	0/ml	200/ml		11/18/25	3:18 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/18/25	9:56 AM	GR DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/18/25	9:56 AM	GR DPD
Turbidity:	1 NTU	1 - 2 NTU	11/18/25	9:56 AM	GR Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor